

Incident Report

Completed by: Boone Brothers

Date: August 27, 2020

Location of Incident: BD
1211 Mary Magnan Blvd.
Madison GA 30650

Release Point: Line 2 Flange # 3813

Date of Incident: August 26, 2020

Description of Incident:

As reported by email on Aug. 26, a maintenance technician identified a flange leak on Line #2 to the RTO while conducting the weekly LDAR Program activities. He tightened the flange bolts as an immediate field action and stopped the leak. The line was taken down for repair and the gasket was replaced and tested. The repair was effective, and no ethylene oxide was detected. The calculated amount released was 0.012 lbs.

Corrective Actions

The site will continue to verify the integrity of the system each week with the LDAR program.